



**UTILITY STANDARDS MANUAL AMENDMENT FORM**

The Authority's Utility Standards Manual is hereby amended as follows:

**Section Being Amended: 7.12 Construction Within Public Rights of Way**


**From:** The On projects in which the General Manager has specifically allowed sanitary sewer system extension(s) to be designed and constructed within public right(s) of way, the following additional materials specifications shall apply:

- A. Pipe Materials – All gravity sewer lines, sewage force mains and sewer service laterals constructed within public rights of way shall be Protecto 401-coated Class 50 Ductile Iron, or approved equal, and shall meet the applicable portions of the specifications in the *Approved Materials List* of this manual.
- B. Tapping Saddles – Where permitted for use, tapping saddles shall be epoxy-coated cast iron with stainless steel bands.

**To:** On projects in which the General Manager has specifically allowed sanitary sewer system extension(s) to be designed and constructed within public right(s) of way, the following additional materials specifications shall apply:

- A. Pipe Materials – All gravity sewer lines, sewage force mains and sewer service laterals constructed within public rights of way shall be Protecto 401-coated Class ~~50~~ 52 Ductile Iron, or approved equal, and shall meet the applicable portions of the specifications in the *Approved Materials List* of this manual.
- B. Tapping Saddles – Where permitted for use, tapping saddles shall be epoxy-coated cast iron with stainless steel bands.

Approved:

  
\_\_\_\_\_  
Phillip "Butch" Parley  
General Manager

6-2-2017  
\_\_\_\_\_  
Date