

FAUQUIER COUNTY WATER AND SANITATION AUTHORITY
7172 KENNEDY ROAD • WARRENTON, VA 20187
PHONE (540) 349-2092 • FAX (540) 347-7689
WEBSITE: fcwsa.org



UTILITY STANDARDS MANUAL AMENDMENT FORM

The Authority's Utility Standards Manual is hereby amended as follows:

Section Being Amended: 3.01 General

From:

Wherever applicable, water lines will be designed to facilitate the implementation of the County Master Water and Sewer Plan. Water lines shall be designed to provide for a looped system wherever feasible at the discretion of the General Manager or Engineer to eliminate dead ends, thereby promoting water quality, adding reliability of service, and efficiently conveying fire flows. In general, water lines shall be located in utility easements dedicated to the Authority, and shall run parallel to and along the routes of roads and/or travel ways. Routes for pipes shall be selected so as to provide the required separations from buildings and other utilities, while minimizing the use of horizontal and vertical bends, and minimizing the number of crossings with curbing and sidewalks. Alternate locations for water lines will be permitted only with the expressed approval of the General Manager.

Water lines shall not be located within Storm Water Management (SWM) and/or BMP facilities or their associated easements. In addition, water lines shall not be located under parking spaces. Storage or stockpiling of dirt or any other materials over buried water lines is prohibited.

Cross fittings are specifically prohibited on water mains. Generally, 2 tees are to be used instead of a cross.

To:


Wherever applicable, water lines will be designed to facilitate the implementation of the County Master Water and Sewer Plan. Water lines shall be designed to provide for a looped system wherever feasible at the discretion of the General Manager or Engineer to eliminate dead ends, thereby promoting water quality, adding reliability of service, and efficiently conveying fire flows. **The maximum length of a permanent dead-end water main is 500 feet. For all commercial, medical, institutional, or industrial establishments with a heightened need for reliability of service, a redundant supply may be required.**

In general, water lines shall be located in utility easements dedicated to the Authority, and shall run parallel to and along the routes of roads and/or travel ways. Routes for pipes shall be selected so as to provide the required separations from buildings and other

utilities, while minimizing the use of horizontal and vertical bends, and minimizing the number of crossings with curbing and sidewalks. Alternate locations for water lines will be permitted only with the expressed approval of the General Manager.

Water lines shall not be located within Storm Water Management (SWM) and/or BMP facilities or their associated easements. In addition, water lines shall not be located under parking spaces. Storage or stockpiling of dirt or any other materials over buried water lines is prohibited.

Cross fittings are specifically prohibited on water mains. Generally, 2 tees are to be used instead of a cross.

Approved: 

Benjamin R. Shoemaker
Executive Director

03/07/2024

Date